MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

RESULTS OF PHYSICAL PROPERTIES OF TMT STEEL

SPECIMENS 8 & 10 mm ,DIA

Date of Testing : 01/04/2023

Grade Of Steel: **Fe 500.**
Technical Ref: IS.1786:2008, IS 1608:2005, IS 1599:1985(Reaffined-2006).

Table

SL No	Grade	Nominal Size of Rebar (Dia)	Mass (KG/meter)	Tensile Strength		
				20% Proof Stress / Yeild Stress (N/mm2)	Tensile Strength (N/ mm2)	Elongation Percent on gauge Length
1.	Fe 500	8 mm	.395	530	530	13.60
2.	Fe 500	10mm	.61	555	570	14.75
3.	Fe 500	12mm	.89	560	590	14.50

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪ ಬೆಂಗಳೂರು-26

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

RESULTS OF PHYSICAL PROPERTIES OF TMT STEEL

SPECIMENS 8 & 10 mm ,DIA

Date of Testing : 20/04/2023

Grade Of Steel: **Fe 500.**
Technical Ref: IS.1786:2008, IS 1608:2005, IS 1599:1985(Reaffined-2006).

Table

SL No	Grade	Nominal Size of Rebar (Dia)	Mass (KG/meter)	Tensile Strength		
				20% Proof Stress / Yeild Stress (N/mm2)	Tensile Strength (N/mm2)	Elongation Percent on gauge Length
1.	Fe 500	8 mm	.33	560	560	13.80
2.	Fe 500	10mm	.65	572	580	14.65
3.	Fe 500	12mm	.84	540	590	14.80

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪ ಬಂಗಳೂರು-26

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 11/04/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	In Front of Honda Showroom, And Cross roads 1 and 2	04-04-2023	11-04-2023	8.20	7	366.00	16.27	15.56
2		"	"	8.10	"	385.00	17.11	
3		"	"	8.25	"	350.00	15.56	
4		"	"	8.30	"	330.00	14.67	
5		"	"	8.40	"	325.00	14.44	
6		"	"	8.15	"	345.00	15.33	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರ
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 02/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	Compressive Strength	Average Strength N/mm2
1	In Front of Honda Showroom, And Cross roads 1 and 2	04-04-2023	02-05-2023	8.40	28	595.00	26.44	25.19
2		"	"	8.00	"	570.00	25.33	
3		"	"	8.45	"	550.00	24.44	
4		"	"	8.25	"	540.00	24.00	
5		"	"	8.20	"	560.00	24.89	
6		"	"	8.15	"	585.00	26.00	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 15/04/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	In Front of Honda Showroom ,Cross road 3 & Cross Road to 3rd Cross Road LHS and RHS	08-04-2023	15-04-2023	8.30	7	360.00	16.00	17.19
2		"	"	8.20	"	390.00	17.33	
3		"	"	8.10	"	420.00	18.67	
4		"	"	8.20	"	400.00	17.78	
5		"	"	8.10	"	390.00	17.33	
6		"	"	8.00	"	360.00	16.00	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 06/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	Compressive Strength	Average Strength N/mm2
1	In Front of Honda Showroom,Cross road 3 & Cross Road to 3rd Cross Road LHS and RHS	08-04-2023	06-05-2023	8.22	28	565.00	25.11	23.53
2		"	"	8.50	"	540.00	24.00	
3		"	"	8.30	"	500.00	22.22	
4		"	"	8.20	"	510.00	22.67	
5		"	"	8.35	"	540.00	24.00	
6		"	"	8.15	"	521.00	23.16	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 17/04/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Vidya Sagar Road LHS and RHS	10-04-2023	17-04-2023	8.20	7	385.00	17.11	16.13
2		"	"	8.30	"	366.00	16.27	
3		"	"	8.10	"	380.00	16.89	
4		"	"	8.30	"	350.00	15.56	
5		"	"	8.00	"	341.00	15.16	
6		"	"	8.10	"	356.00	15.82	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿಬಿಎಂಪಿ ಬೆಂಗಳೂರು-26

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 08/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	Compressive Strength	Average Strength N/mm2
1	Vidya Sagar Road LHS and RHS	10-04-2023	08-05-2023	8.15	28	545.00	24.22	24.39
2		"	"	8.55	"	555.00	24.67	
3		"	"	8.20	"	530.00	23.56	
4		"	"	8.30	"	580.00	25.78	
5		"	"	8.40	"	520.00	23.11	
6		"	"	8.20	"	562.00	24.98	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-24

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 19/04/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Opp to Masjid Road	12-04-2023	19-04-2023	8.03	7	390.00	17.33	18.05
2		"	"	8.20	"	410.00	18.22	
3		"	"	8.15	"	422.00	18.76	
4		"	"	8.30	"	410.00	18.22	
5		"	"	8.45	"	400.00	17.78	
6		"	"	8.30	"	405.00	18.00	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 10/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	Compressive Strength	Average Strength N/mm2
1	Opp to Masjid Road	12-04-2023	10-05-2023	8.12	28	490.00	21.78	23.00
2		"	"	8.36	"	500.00	22.22	
3		"	"	8.22	"	510.00	22.67	
4		"	"	8.20	"	520.00	23.11	
5		"	"	8.30	"	555.00	24.67	
6		"	"	8.45	"	530.00	23.56	

SHRIYA CONSTRUCTION AND CONSULTANCY

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 22/04/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Bachanna Krishnappa Layout LHS & RHS Ashawath nagar Drains	15-04-2023	22-04-2023	8.20	7	345.00	15.33	15.71
2		"	"	8.30	"	365.00	16.22	
3		"	"	8.50	"	395.00	17.56	
4		"	"	8.45	"	362.00	16.09	
5		"	"	8.20	"	342.00	15.20	
6		"	"	8.00	"	312.00	13.87	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 13/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Bachanna Krishnappa Layout LHS & RHS Ashawathnagar Drains	15-04-2023	13-05-2023	8.00	28	545.00	24.22	23.30
2		"	"	8.20	"	595.00	26.44	
3		"	"	8.35	"	485.00	21.56	
4		"	"	8.40	"	490.00	21.78	
5		"	"	8.30	"	530.00	23.56	
6		"	"	8.30	"	500.00	22.22	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 25/04/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Iqra School Road Drain	18-04-2023	25-04-2023	8.33	7	394.00	17.51	18.19
2		"	"	8.41	"	411.00	18.27	
3		"	"	8.30	"	452.00	20.09	
4		"	"	8.10	"	419.00	18.62	
5		"	"	8.00	"	400.00	17.78	
6		"	"	8.25	"	379.00	16.84	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 16/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Iqra School Road Drain	18-04-2023	16-05-2023	8.21	28	510.00	22.67	23.16
2		"	"	8.23	"	532.00	23.64	
3		"	"	8.28	"	522.00	23.20	
4		"	"	8.10	"	543.00	24.13	
5		"	"	8.15	"	508.00	22.58	
6		"	"	8.43	"	511.00	22.71	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಪ್ರಾಜೆಕ್ಟ್ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 28/04/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Baloon Factory Road Drain And Road Till Apartment	21-04-2023	28-04-2023	8.61	7	419.00	18.62	17.33
2		"	"	8.34	"	405.00	18.00	
3		"	"	8.51	"	360.00	16.00	
4		"	"	8.56	"	380.00	16.89	
5		"	"	8.41	"	395.00	17.56	
6		"	"	8.23	"	380.00	16.89	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-24

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 19/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Baloon Factory Road Drain And Road Till Apartment	21-04-2023	19-05-2023	8.41	28	522.00	23.20	23.35
2		"	"	8.35	"	533.00	23.69	
3		"	"	8.27	"	515.00	22.89	
4		"	"	8.22	"	542.00	24.09	
5		"	"	8.35	"	535.00	23.78	
6		"	"	8.14	"	505.00	22.44	

SHRIYA CONSTRUCTION AND CONSULTANCY

MOBILE 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 01/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Bagari Nivas Road, 2nd A Cross Road, Motanna Layout	24-04-2023	01-05-2023	8.50	7	395.00	17.56	17.29
2		"	"	8.30	"	385.00	17.11	
3		"	"	8.40	"	360.00	16.00	
4		"	"	8.20	"	380.00	16.89	
5		"	"	8.22	"	399.00	17.73	
6		"	"	8.15	"	415.00	18.44	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-24

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 22/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Bagari Nivas Road, 2nd A Cross Road, Motanna Layout	24-04-2023	22-05-2023	8.50	28	515.00	22.89	23.25
2		"	"	8.40	"	562.00	24.98	
3		"	"	8.30	"	540.00	24.00	
4		"	"	8.20	"	500.00	22.22	
5		"	"	8.35	"	505.00	22.44	
6		"	"	8.15	"	517.00	22.98	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿಬಿಎಂಪಿ ಬೆಂಗಳೂರು-26

MOBILE 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 04/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table 1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Sairaipalya Main Road LHS and RHS	27-04-2023	04-05-2023	8.30	7	400.00	17.78	16.72
2		"	"	8.25	"	405.00	18.00	
3		"	"	8.41	"	355.00	15.78	
4		"	"	8.52	"	375.00	16.67	
5		"	"	8.39	"	345.00	15.33	
6		"	"	8.19	"	377.00	16.76	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 25/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table 1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Sairaipalya Main Road LHS and RHS	27-04-2023	25-05-2023	8.33	28	500.00	22.22	23.35
2		"	"	8.26	"	490.00	21.78	
3		"	"	8.15	"	535.00	23.78	
4		"	"	8.39	"	563.00	25.02	
5		"	"	8.43	"	545.00	24.22	
6		"	"	8.38	"	519.00	23.07	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

Date: 07/05/2023

NO: BTP- D/PMC/Tani/Raft

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table 1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	#45/47 Manzil Road, 10th C/s Road, Vinayaka nagar and Tawakal Chicken Centre Road	30-04-2023	07-05-2023	8.54	7	422.00	18.76	18.53
2		"	"	8.63	"	416.00	18.49	
3		"	"	8.52	"	423.00	18.80	
4		"	"	8.26	"	438.00	19.47	
5		"	"	8.17	"	418.00	18.58	
6		"	"	8.15	"	385.00	17.11	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-೨೬

MOBILE 9945744739

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani/Raft

Date: 28/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	#45/47 Manzil Road, 10th C/s Road, Vinayaka nagar and Tawakal Chicken Centre Road	30-04-2023	28-05-2023	8.25	28	540.00	24.00	23.32
2		"	"	8.29	"	525.00	23.33	
3		"	"	8.27	"	563.00	25.02	
4		"	"	8.14	"	495.00	22.00	
5		"	"	8.35	"	510.00	22.67	
6		"	"	8.25	"	515.00	22.89	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿಬಿಎಂಪಿ ಬೆಂಗಳೂರು-26

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 19/04/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	In Front of Honda Showroom , And Cross roads 1 and 2	12-04-2023	19-04-2023	8.33	7	398.00	17.69	16.77
2		"	"	8.23	"	352.00	15.64	
3		"	"	8.24	"	360.00	16.00	
4		"	"	8.25	"	378.00	16.80	
5		"	"	7.90	"	391.00	17.38	
6		"	"	7.95	"	385.00	17.11	

SHRIYA CONSTRUCTION AND CONSULTANCY

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 10/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	In Front of Honda Showroom , And Cross roads 1 and 2	12-04-2023	10-05-2023	8.10	28	560.00	24.89	25.00
2		"	"	8.00	"	568.00	25.24	
3		"	"	8.25	"	581.00	25.82	
4		"	"	8.24	"	597.00	26.53	
5		"	"	8.15	"	549.00	24.40	
6		"	"	8.25	"	520.00	23.11	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 22/04/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	In Front of Honda Showroom ,Cross road 3 & Cross Road to 3rd Cross Road LHS and RHS	15-04-2023	22-04-2023	8.15	7	390.00	17.33	17.63
2		"	"	8.32	"	410.00	18.22	
3		"	"	8.15	"	430.00	19.11	
4		"	"	8.00	"	400.00	17.78	
5		"	"	8.25	"	385.00	17.11	
6		"	"	8.25	"	365.00	16.22	

SHRIYA CONSTRUCTION AND CONSULTANCY

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 13/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	In Front of Honda Showroom ,Cross road 3 & Cross Road to 3rd Cross Road CLHS and RHS	15-04-2023	13-05-2023	8.12	28	575.00	25.56	25.11
2		"	"	8.25	"	524.00	23.29	
3		"	"	8.36	"	615.00	27.33	
4		"	"	8.14	"	542.00	24.09	
5		"	"	8.20	"	573.00	25.47	
6		"	"	8.30	"	561.00	24.93	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 25/04/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Vidya Sagar Road CLHS and RHS	18-04-2023	25-04-2023	8.00	7	421.00	18.71	16.50
2		"	"	8.15	"	357.00	15.87	
3		"	"	8.41	"	385.00	17.11	
4		"	"	8.52	"	364.00	16.18	
5		"	"	8.30	"	350.00	15.56	
6		"	"	8.05	"	350.00	15.56	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಧಿಯಂತರವರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-೨೬

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 16/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table 1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Vidya Sagar Road LHS and RHS	18-04-2023	16-05-2023	8.05	28	520.00	23.11	22.73
2		"	"	8.21	"	532.00	23.64	
3		"	"	8.65	"	517.00	22.98	
4		"	"	8.30	"	518.00	23.02	
5		"	"	8.40	"	480.00	21.33	
6		"	"	8.20	"	502.00	22.31	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 28/04/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Opp to Masjid Road	21-04-2023	28-04-2023	8.20	7	395.00	17.56	17.64
2		"	"	8.40	"	400.00	17.78	
3		"	"	8.20	"	415.00	18.44	
4		"	"	8.05	"	402.00	17.87	
5		"	"	8.10	"	380.00	16.89	
6		"	"	8.36	"	389.00	17.29	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-26

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 19/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Opp to Masjid Road	21-04-2023	19-05-2023	8.21	28	480.00	21.33	22.77
2		"	"	8.23	"	520.00	23.11	
3		"	"	8.28	"	530.00	23.56	
4		"	"	8.10	"	560.00	24.89	
5		"	"	8.15	"	485.00	21.56	
6		"	"	8.43	"	499.00	22.18	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯ[illegible] ಅಭಿಯಂತರರ
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿಬಿಎಂಪಿ ಬೆಂಗಳೂರು-26

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 01/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Bachanna Krishnapp a Layout LHS & RHS Ashawath nagar Drains	24-04-2023	01-05-2023	8.40	7	395.00	17.56	17.65
2		"	"	8.34	"	419.00	18.62	
3		"	"	8.40	"	430.00	19.11	
4		"	"	8.56	"	385.00	17.11	
5		"	"	8.41	"	369.00	16.40	
6		"	"	8.23	"	385.00	17.11	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 22/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K L shmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Bachanna Krishnapp a Layout LHS & RHS Ashawath nagar Drains	24-04-2023	22-05-2023	8.35	28	555.00	24.67	24.36
2		"	"	8.42	"	537.00	23.87	
3		"	"	71	"	578.00	25.69	
4		"	"	8.20	"	536.00	23.82	
5		"	"	8.00	"	521.00	23.16	
6		"	"	8.15	"	562.00	24.98	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪ ಬೆಂಗಳೂರು-26

MOBILE 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 04/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Iqra School Road Drain	27-04-2023	04-05-2023	8.22	7	400.00	17.78	17.30
2		"	"	8.41	"	375.00	16.67	
3		"	"	8.25	"	385.00	17.11	
4		"	"	8.63	"	385.00	17.11	
5		"	"	8.45	"	390.00	17.33	
6		"	"	8.32	"	400.00	17.78	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪ ಬೆಂಗಳೂರು-24

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 25/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Iqra School Road Drain	27-04-2023	25-05-2023	8.00	28	520.00	23.11	22.63
2		"	"	8.23	"	541.00	24.04	
3		"	"	8.35	"	500.00	22.22	
4		"	"	8.17	"	510.00	22.67	
5		"	"	8.59	"	485.00	21.56	
6		"	"	8.65	"	499.00	22.18	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-28

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 07/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Baloon Factory Road Drain And Road Till Apartment	30-04-2023	07-05-2023	8.30	7	405.00	18.00	18.32
2		"	"	8.15	"	423.00	18.80	
3		"	"	8.62	"	431.00	19.16	
4		"	"	8.41	"	387.00	17.20	
5		"	"	8.55	"	399.00	17.73	
6		"	"	8.36	"	428.00	19.02	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪ ಬೆಂಗಳೂರು-26

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 28/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Baloon Factory Road Drain And Road Till Apartment	30-04-2023	28-05-2023	8.14	28	543.00	24.13	24.21
2		"	"	8.61	"	585.00	26.00	
3		"	"	8.25	"	547.00	24.31	
4		"	"	8.36	"	512.00	22.76	
5		"	"	8.10	"	532.00	23.64	
6		"	"	8.00	"	550.00	24.44	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 11/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Bagari Nivas Road, 2nd A Cross Road, Motanna Layout	04-05-2023	11-05-2023	8.20	7	400.00	17.78	17.30
2		"	"	8.30	"	380.00	16.89	
3		"	"	8.24	"	390.00	17.33	
4		"	"	8.42	"	370.00	16.44	
5		"	"	8.21	"	390.00	17.33	
6		"	"	8.36	"	405.00	18.00	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 01/06/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Bagari Nivas Road, 2nd A Cross Road, Motanna Layout	04-05-2023	01-06-2023	8.10	28	540.00	24.00	22.53
2		"	"	8.36	"	520.00	23.11	
3		"	"	8.52	"	500.00	22.22	
4		"	"	8.41	"	503.00	22.36	
5		"	"	8.25	"	493.00	21.91	
6		"	"	8.39	"	485.00	21.56	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪ ಬೆಂಗಳೂರು-೨೬

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 16/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Sairaipalya Main Road LHS and RHS	09-05-2023	16-05-2023	8.32	7	395.00	17.56	17.50
2		"	"	8.25	"	405.00	18.00	
3		"	"	8.36	"	415.00	18.44	
4		"	"	8.18	"	375.00	16.67	
5		"	"	8.50	"	373.00	16.58	
6		"	"	8.20	"	399.00	17.73	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 06/06/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Sairaipalya Main Road LHS and RHS	09-05-2023	06-06-2023	8.15	28	510.00	22.67	22.25
2		"	"	8.23	"	495.00	22.00	
3		"	"	8.20	"	485.00	21.56	
4		"	"	8.14	"	499.00	22.18	
5		"	"	8.30	"	505.00	22.44	
6		"	"	8.40	"	510.00	22.67	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 22/05/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	#45/47 Manzil Road, 10th C/s Road, Vinayaka nagar and Tawakal Chicken Centre Road	15-05-2023	22-05-2023	8.10	7	390.00	17.33	16.32
2		"	"	8.25	"	385.00	17.11	
3		"	"	8.32	"	385.00	17.11	
4		"	"	8.29	"	368.00	16.36	
5		"	"	8.27	"	375.00	16.67	
6		"	"	8.00	"	300.00	13.33	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ.

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/ Tani /Side Walls

Date: 12/06/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm

Grade Of concrete: **M20**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	#45/47 Manzil Road, 10th C/s Road, Vinayaka nagar and Tawakal Chicken Centre Road	15-05-2023	12-06-2023	8.23	28	509.00	22.62	23.30
2		"	"	8.14	"	517.00	22.98	
3		"	"	8.36	"	538.00	23.91	
4		"	"	8.25	"	539.00	23.96	
5		"	"	8.22	"	543.00	24.13	
6		"	"	8.32	"	500.00	22.22	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani /M30 Road

Date: 23/06/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: **M30**
Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Roads - In Front of Honda Showroom , Cross Roads 1,2,3 and Cross road to 3 rd C/s Road	16-06-2023	23-06-2023	8.54	7	499.00	22.18	23.64
2		"	"	8.25	"	426.00	18.93	
3		"	"	8.63	"	503.00	22.36	
4		"	"	8.55	"	500.00	22.22	
5		"	"	8.12	"	479.00	21.29	
6		"	"	8.34	"	785.00	34.89	

SHRIYA CONSTRUCTION AND CONSULTANCY

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani /M30 Road

Date: 14/07/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: **M30**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Roads - In Front of Honda Showroom , Cross Roads 1,2,3 and Cross road to 3 rd C/s Road	16-06-2023	14-07-2023	8.65	28	705.00	31.33	33.74
2		"	"	8.42	"	736.00	32.71	
3		"	"	8.63	"	800.00	35.56	
4		"	"	8.24	"	767.00	34.09	
5		"	"	8.25	"	784.00	34.84	
6		"	"	8.54	"	763.00	33.91	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

MOBILE:9945744750

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

Date: 23/06/2023

NO: BTP- D/PMC/Tani /M30 Road

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: M30
Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Roads - In Front of Honda Showroom , Cross Roads 1,2,3 and Cross road to 3 rd C/s Road	16-06-2023	23-06-2023	8.24	7	475.00	21.11	20.70
2		"	"	8.36	"	469.00	20.84	
3		"	"	8.52	"	485.00	21.56	
4		"	"	8.44	"	436.00	19.38	
5		"	"	8.25	"	455.00	20.22	
6		"	"	8.63	"	475.00	21.11	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-೫೫

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

Date: 14/07/2023

NO: BTP- D/PMC/Tani /M30 Road

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: M30

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Roads - In Front of Honda Showroom , Cross Roads 1,2,3 and Cross road to 3 rd C/s Road	16-06-2023	14-07-2023	8.63	28	799.00	35.51	34.65
2		"	"	8.52	"	806.00	35.82	
3		"	"	8.43	"	756.00	33.60	
4		"	"	8.55	"	784.00	34.84	
5		"	"	8.41	"	788.00	35.02	
6		"	"	8.25	"	745.00	33.11	

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE 9945744739

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani /M30 Road

Date: 27/06/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: **M30**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strength N/mm2	Average Strength N/mm2
1	Saraipalya Main road, Cross Roads 1,2,3 and Next to Masjid	20-06-2023	27-06-2023	8.22	7	488.00	21.69	20.99
2		"	"	8.36	"	443.00	19.69	
3		"	"	8.51	"	475.00	21.11	
4		"	"	8.64	"	488.00	21.69	
5		"	"	8.45	"	468.00	20.80	
6		"	"	8.27	"	472.00	20.98	

SHRIYA CONSTRUCTION AND CONSULTANCY

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani /M30 Road

Date: 18/07/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: **M30**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Saraipalya Main road, Cross Roads 1,2,3 and Next to Masjid	20-06-2023	18-07-2023	8.41	28	796.00	35.38	34.84
2		"	"	8.52	"	755.00	33.56	
3		"	"	8.65	"	748.00	33.24	
4		"	"	8.39	"	798.00	35.47	
5		"	"	8.21	"	830.00	36.89	
6		"	"	8.46	"	777.00	34.53	

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani /M30 Road

Date: 29/06/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days - Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: **M30**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Devi Temple Road, HN. 6/A, 59 Road, Bachanna Krishnapp a Road	22-06-2023	29-06-2023	8.23	7	467.00	20.76	20.63
2		"	"	8.32	"	463.00	20.58	
3		"	"	8.14	"	475.00	21.11	
4		"	"	8.24	"	424.00	18.84	
5		"	"	8.26	"	458.00	20.36	
6		"	"	8.22	"	498.00	22.13	

SHRIYA CONSTRUCTION AND CONSULTANCY

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani /M30 Road

Date: 20/07/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: **M30**
Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Devi Temple Road, HN. 6/A, 59 Road, Bachanna Krishnapp a Road	22-06-2023	20-07-2023	8.36	28	805.00	35.78	34.06
2		"	"	8.14	"	756.00	33.60	
3		"	"	8.50	"	725.00	32.22	
4		"	"	8.36	"	749.00	33.29	
5		"	"	8.51	"	798.00	35.47	
6		"	"	8.10.	"	765.00	34.00	

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani /M30 Road

Date: 03/07/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days - Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: **M30**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Ashwathn agara Roads	26-06-2023	03-07-2023	8.55	7	400.00	17.78	20.48
2		"	"	4.52	"	456.00	20.27	
3		"	"	8.49	"	474.00	21.07	
4		"	"	8.57	"	485.00	21.56	
5		"	"	8.24	"	469.00	20.84	
6		"	"	8.63	"	481.00	21.38	

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE:9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani /M30 Road

Date: 24/07/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: **M30**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Ashwathn agara Roads	26-06-2023	24-07-2023	8.67	28	746.00	33.16	34.27
2		"	"	8.54	"	794.00	35.29	
3		"	"	8.63	"	758.00	33.69	
4		"	"	8.54	"	769.00	34.18	
5		"	"	8.69	"	782.00	34.76	
6		"	"	8.50	"	777.00	34.53	

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE: 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani /M30 Road

Date: 05/07/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days - Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: **M30**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Awa Store Road, #91, Motanna Layout Roads	28-06-2023	05-07-2023	8.32	7	468.00	20.80	20.93
2		"	"	8.12	"	465.00	20.67	
3		"	"	8.23	"	474.00	21.07	
4		"	"	8.17	"	465.00	20.67	
5		"	"	8.23	"	455.00	20.22	
6		"	"	8.38	"	499.00	22.18	

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರ
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬೆಂಗಳೂರು-26

MOBILE 9945744739

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani /M30 Road

Date: 26/07/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: **M30**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Awa Store Road, #91, Motanna Layout Roads	28-06-2023	26-07-2023	8.25	28	769.00	34.18	34.52
2		"	"	8.36	"	784.00	34.84	
3		"	"	8.24	"	765.00	34.00	
4		"	"	8.37	"	788.00	35.02	
5		"	"	8.57	"	748.00	33.24	
6		"	"	8.66	"	806.00	35.82	

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

SHRIYA CONSTRUCTION AND CONSULTANCY

MOBILE:9945744759

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani /M30 Road

Date: 26/07/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days - Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: **M30**
Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Javera School Road, Next to Masjid Road	19-07-2023	26-07-2023	8.25	7	485.00	21.56	21.36
2		"	"	8.36	"	496.00	22.04	
3		"	"	8.27	"	475.00	21.11	
4		"	"	8.25	"	475.00	21.11	
5		"	"	8.36	"	453.00	20.13	
6		"	"	8.41	"	499.00	22.18	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪಿ ಬೆಂಗಳೂರು-26

MOBILE 9945744759

SHRIYA CONSTRUCTION AND CONSULTANCY

#1133, 3rd Floor, 3rd Stage, 'B' Cross, Yelahanka New Town Bangalore 560064.

NO: BTP- D/PMC/Tani /M30 Road

Date: 16/08/2023

Test report on cement Concrete Cubes:

Sub: Testing of concrete cubes (for below said no of days – Compressive Strength)

Name of Work :- CONSTRUCTION OF DRAINS AND CULVERTS IN THANISANDRA VILLAGE AND SARAIPALYA AND SURROUNDING AREAS IN WARD NO. 06, NEW WARD NO. 07.

Ref: Material Testing/PMC/22-23.

Report submitted to: Assistant Executive Engineer, Byatarayanapura Division, BBMP Bangalore.

Name of Agency/ contractor: M/s Sri K Lakshmi Narayan Reddy.

RESULTS OF COMPRESSIVE STRENGHT OF CONCRETE CUBES

CUBE SPECIMENS

Dimentions of Specimens: 150x150x150mm
Grade Of concrete: **M30**

Table1.1

Sl No	Location	Date Of Casting	Date Of Testing	Weight Of Cubes	Age in days	Load (KN)	ssive Strengt h N/mm2	Average Strength N/mm2
1	Javera School Road, Next to Masjid Road	19-07-2023	16-08-2023	8.22	28	746.00	33.16	33.58
2		"	"	8.32	"	754.00	33.51	
3		"	"	8.63	"	774.00	34.40	
4		"	"	8.27	"	742.00	32.98	
5		"	"	8.17	"	765.00	34.00	
6		"	"	8.38	"	752.00	33.42	

SHRIYA CONSTRUCTION AND CONSULTANCY

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪ ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿ.ಬಿ.ಎಂ.ಪ ಬೆಂಗಳೂರು-೨೬